



**ISTITUTO  
GIORDANO**  
Qualità al Plurale.

**Istituto Giordano S.p.A.**

Cod. Fis./P. Ia 00 549 540 409 - Cap. Soc. € 880.000 i.v.

R.E.A. do C.C.I.A.A. (RN) 156766

Registro Imprese di Rimini n. 00 549 540 409

Organismo Europeo notificato n. 0407

Accreditamenti: SINCERT (057A e 082B) - SINAL (0021) - SIT (multisede 20)

**LABORATORIO REAZIONE AL FUOCO**

Via Verga, 10 - 47043 Gatteo (FC) Italy

Tel. +39 0541 818582 - Fax +39 0541 818074 - [reazionealfuoco@giordano.it](mailto:reazionealfuoco@giordano.it)

**TELEFAX**

Data / Date: 08/07/2008

Ns. rif. / Our ref.: Commessa n. 41194

Alla Società / To company: **ÀIGNEP**

Attenzione / For the attention of: **ing. Massimo Salvинelli**

N. Telefono / Tel. n.: 0365 896626

N. telefax / Fax n.: 0365 896561

Da / From: **Reaction to Fire Laboratory**

N. telefonico interno / Internal: 0541 818582 102

Oggetto / Subject: **Reaction to Fire Classification**

N. pagine: / N. of pages: 1

Messaggio / Message:

**Subject**

Fire classification of construction products and building elements, based on the results of reaction to fire testing in accordance with UNI EN 13501-1:2005.

**Description of the product** (according to information supplied by The Customer)

Painted aluminium pipe SERIES 90.000.

Classification was determined by analysis of the paint's gross heat of combustion, coupled with test results as specified in UNI EN ISO 13823 on equivalent flat sheets, having the same thickness of aluminium and paint as the pipe.

**Test Results**

The product under test has been awarded Reaction to Fire Class A1, in accordance with test results obtained.

*The official report will follow, kind regards*

*The Manager of Reaction to Fire Laboratory*

*Dott. Gian Luigi Baffoni*